



Transnet SOC Limited
Transnet RME

REQUEST FOR QUOTATION

BOARD LIST TFR RME
TRANSNET FREIGHT RAIL - RME
PROCUREMENT DEPARTMENT
2000

Registration Number: 1990/000900/30
Vat Number : 4720103177

Attention:

Telephone Number :
Fax Number :
Vendor Number :2004815

Quotation Deadline Date : 15.06.2015
Quotation Deadline Time : 12:00

REQUEST for QUOTATION
Transnet RME
RFQ Number / Date
6000227240 / 04.06.2015
Contact Person / Telephone
Mari Maritz / 035 906 7348
Return to VAX Number/EMAIL
0835159978 / TCPtendersRichardsBay@Transnet.net

PREVIEW COPY ONLY

Item	Material	Description	RFQ Qty	UoM	Required Del date	Confirm Del date	Unit Price Excl	Total Price Excl
00010		Vapourline VLN 1 X 35w/	20	ea	30.06.2015			

Vapourline VLN 1 X 35w/BMK/EMERGENCY/Industrial corrosion resistant fluorescent light fitting or equivalent

Transnet Limited t/a Transnet Freight Rail RME # Richards Bay hereby invite your company to supply a detailed quotation to provide/supply and deliver the following:

Supply and delivery of 20 off Vapourline VLN 1 X 35w/BMK/EMERGENCY/Industrial corrosion resistant fluorescent light fitting or equivalent

Notes:

1. Price should include delivery to Richards Bay
2. Please make sure to submit returnable documents
3. Refer to attached specification of goods
4. Transnet desires a validity period of 90 [ninety] days from the closing date of this RFQ.

All technical queries relating to this request may be addressed to: Marius Potgieter - 035 905 3524 / 083 743 3950. All procurement relating queries can be addressed to the Mari Maritz - 035 906 7348.

The closing time for receipt of your official quotations is: 12:00 hrs on Monday, the 15th of June 2015.



Transnet SOC Limited
 Transnet RME
 BOARD LIST TFR RME
 TRANSNET FREIGHT RAIL - RME
 PROCUREMENT DEPARTMENT
 2000
 YOUR VAT NUMBER WITH US: NOT

REQUEST FOR QUOTATION

Registration Number: 1990/000900/30
 Vat Number : 4720103177

Attention:

Telephone Number :
 Fax Number :
 Vendor Number :2004815

Quotation Deadline Date : 15.06.2015
Quotation Deadline Time : 12:00

REQUEST for QUOTATION

Transnet RME

RFQ Number / Date

6000227240 / 04.06.2015

Contact Person / Telephone

Mari Maritz / 035 906 7348

Return to VAX Number/EMAIL

0865159978 / TCPtendersRichardsBay@Transnet.net

Item	Material	Description	RFQ Qty	UoM	Required Del date	Confirm Del date	Unit Price Excl	Total Price Excl
------	----------	-------------	---------	-----	-------------------	------------------	-----------------	------------------

Telephonic and late quotes will not be accepted. All quotations should be submitted via fax to 086 515 9978 or alternatively e-mailed to tcpptendersrichardsbay@transnet.net

Procurement Official - Attention: Yogeshnie Gengan

Identification details:

Quotation / Reference number: ERAC-EMU-17643-MM-018

Description: Supply and delivery of 20 off Vapourline VLN 1 X 35w/3MK/EMERGENCY/Industrial corrosion resistant fluorescent light fitting or equivalent

The supplier's/ contractor's address and identification details have to be shown on each quotation received.

a) Respondents are required to submit with their Quotations the mandatory Returnable Documents, as detailed below:

1. Specification of goods offered

Failure to provide this Mandatory Returnable Document at the Closing Date and time of this RFQ will result in a Respondent's disqualification.

b) In addition to the requirements of section (a) above, Respondents are further required to submit with their Quotations the following essential Returnable Documents as detailed below:

1. Valid Tax Clearance certificate.
2. Copy of your latest B.B.B.E.E. Certificate.

Note: #Transnet may not necessarily accept the lowest or any other offer and reserves the right to select in its favor any or, a portion of any offer made". If you are unable to quote for this survey, please submit a NO QUOTE, with a short reasons, if possible, for not being able to quote. Otherwise we look forward to receive your quote by the date and time stated.



Transnet SOC Limited
Transnet RME
 BOARD LIST TFR RME
 TRANSNET FREIGHT RAIL - RME
 PROCUREMENT DEPARTMENT
 2000
 YOUR VAT NUMBER WITH US: NOT

REQUEST FOR QUOTATION

Registration Number: 1990/000900/30
Vat Number : 4720103177

Attention:
 Telephone Number :
 Fax Number :
 Vendor Number :2004815

Quotation Deadline Date : 15.06.2015
Quotation Deadline Time : 12:00

REQUEST for QUOTATION
 Transnet RME
RFQ Number / Date
 6000227240 / 04.06.2015
Contact Person / Telephone
 Mari Maritz / 035 906 7348
Return to VAX Number/EMAIL
 0865159978 / TCPtendersRichardsBay@Transnet.net

Item	Material	Description	RFQ Qty	UoM	Required Del date	Confirm Del date	Unit Price Excl	Total Price Excl
------	----------	-------------	---------	-----	-------------------	------------------	-----------------	------------------

Delivery address: Old Naval base, 100 Commodores close, Meerensee, Richards Bay

"PREVIEW COPY ONLY"



REQUEST FOR QUOTATION

Transnet SOC Limited
 Transnet RME
 BOARD LIST TFR RME
 TRANSNET FREIGHT RAIL - RME
 PROCUREMENT DEPARTMENT
 2000
 YOUR VAT NUMBER WITH US: NOT

Registration Number: 1990/000900/30
 Vat Number : 4720103177

Attention:

Telephone Number :
 Fax Number :
 Vendor Number :2004815

Quotation Deadline Date : 15.06.2015
Quotation Deadline Time : 12:00

REQUEST for QUOTATION

Transnet RME

RFQ Number / Date

6000227240 / 04.06.2015

Contact Person / Telephone

Mari Maritz / 035 906 7348

Return to VAX Number/EMAIL

0865159978 / TCPtendersRichardsBay@Transnet.net

Delivery Address

TFR RME Richards Bay
 Old Naval Base, Commodores Clo
 Meerensee, Richards Bay
 3900

This RFQ is subject to the following conditions:

1. Price/s : The price/s quoted in SA currency and is excluding of V.A.T
2. Delivery : The price/s quoted should include delivery cost to the delivery address stated on the RFQ
3. Returnables : A valid tax clearance certificate and BBBEE certificate from a SANAS accredited verification agency attached to quotation for all quotes above R30 000.
Please note that only the official Transnet RFQ will be accepted and all other correspondence to be attached to the original
4. Safety : To confirm to Transnet Freight Rail RME Health & Safety plan and specification; HAS-std-0001, copy available on request.
5. Confirmation: To confirm your participation in this tender process please sign and return this document as immediate effect prior to the quotation deadline.
6. Negotiations: The Employer may elect to negotiate the final terms of the contract/order with the preferred tenderer in accordance with Clauses F.2.17 and F.3.13 of the CIDB Standard Conditions of Tender. A copy of which is available upon request.
7. Quotes will not be acceptable if not sending to the given fax or e-mail (please do not CC any buyer)
8. Should your company not receive any response from Transnet within 30 days of closing of a RFQ, please accept that your quotation was unsuccessful.

 Signature

 Date

VAPOURLINE – VLN 1 x 35W/BMK/ EM/ ECG/Industrial Corrosion resistant fluorescent luminaire

The luminaire shall consist of an injection-moulded, flame-retardant polycarbonate housing and prismatic diffuser. The powder coated white reflector and control gear tray, upon which all electrical components are mounted, shall be secured by means of multiple twist lock latches to secure the reflector to the housing. The silicon sponge seal shall be moulded into the housing to ensure an optimal seal between the housing and the prismatic diffuser. Two of the stainless steel latches shall facilitate the hinging of the diffuser and shall ensure correct alignment when closing the diffuser. It shall be designed to operate fluorescent lamps 1*35W.

The luminaire shall bear the SANS 475 performance mark and the SANS 60598-2-1 safety mark.
The luminaire shall have a degree of protection that complies with SANS 60598-2-1.

Lamp compartment: IP65

Gear compartment: IP65

The body shall be manufactured from injection-moulded, flame-retardant polycarbonate material. Mounting shall be facilitated through removable external stainless steel mounting brackets, which can accommodate either surface or suspension mounting. A 20mm gland entry shall be provided at one end with a knock out at the opposite end, making it suitable for surface or through wiring. A silicon sponge gasket shall be fitted into a special groove in the housing. This, in conjunction with the tongue provided on the diffuser, shall ensure the optimal sealing of the total enclosure, thereby maintaining the certified IP65 ingress protection rating.

The diffuser shall be manufactured from the same material as the housing, thus ensuring the flame-retardant integrity of the luminaire. The highly effective internal prisms of the diffuser shall ensure an optimal distribution of more than 90%. The diffuser shall be secured in place through 10 sprung stainless steel clips which shall ensure the integrity of the IP rating. Two of these clips shall keep the diffuser attached to the luminaire when hinges open, for ease of lamp replacement.

The ballast and all auxiliary components shall be mounted on the reverse side of the powder coated steel reflector and shall be accessible for maintenance. The internal reflector and control gear tray shall be attached to the body of the luminaire by multiple winged shaped fasteners. Two removable control gear tray straps shall suspend the reflector and control gear tray when released from the body, for ease of maintenance. The electronic control gear shall be suitable for operation with the specified lamps on a 230V +3%/-10% at 50Hz, single phase supply. All control gear components shall be removable and bear the relevant SABS mark. Mains connections shall be by means of a suitable screw terminal block with a wire clamping contact. The luminaire shall be power factor corrected to 0.95

The luminaire is to have a mass no more or less than 2.2 kg

Colour: RAL7038 only

Luminaire to be assembled only in a SOUTH AFRICAN ISO 9001 facility.

ISO 9001 Certificate to be submitted with tender as well as the SANS 60598-2-1 Certificate and the SANS 475 certificate

Dimensions to strictly comply with the below drawings.

L= 1570mm

W=86mm

H=90mm

LF=1200mm

Number of Stainless steel clips: 10

