


**APPENDIX A: TYPICAL POWER SUPPLY TO CUBICLE/HUT/ENCLOSURE FOR DC ELECTRIFIED AREAS.**



## APPENDIX B: CHARACTERISTICS OF THE QUALITY OF THE 230V AC POWER SUPPLY AT VARIOUS RAILWAY TRACK SIDE INSTALLATIONS

### 1 Introduction

- 1.1 The following is a typical representation of the power supply expected in the vicinity of a traction power line. These characteristics are to be taken into consideration when purchasing power equipment (such as UPS, chargers etc.) for Spoornet's industrial applications.
- 1.2 The data used in these guidelines was extracted from the findings of a Quality of Power Supply investigation on the 230V supply at Elands Bay - Loop 2 on the 50kV AC OREX line.

### 2 The uninterruptible power supply

- 2.1 The power equipment shall not be adversely affected by odd voltage harmonics between the 3<sup>rd</sup> and 13<sup>th</sup> harmonics of which can reach amplitudes as indicated in the following table. The THD can reach maximum amplitudes up to 27%.
- 2.2 The power equipment shall not be subject to degradation when exposed to the voltage Dips with deviations to the magnitudes of -50 % on all the phases.

### 3 Typical Voltage harmonics on the 230V supply

Table 1	Typical Daily Values of Harmonics and THD on the OREX 230V Supply
Harmonic and THD	Highest Daily Values (%)
3 <sup>rd</sup>	12
5 <sup>th</sup>	9
7 <sup>th</sup>	8
11 <sup>th</sup>	14
13 <sup>th</sup>	4
THD	27

4 Typical voltage dips on the 230V supply

<b>Table 2</b>				
<b>Daily Voltage Dips on the OREX 230V Supply</b>				
<b>Time</b>	<b>NRS048</b>	<b>Phases</b>	<b>Duration</b>	<b>Deviation (%)</b>
25:50.8	X	ABC	0.040 s	-28.6
59:53.6	X	ABC	0.020 s	-22.6
59:53.7	X	ABC	0.030 s	-22.6
59:53.7	X	ABC	0.030 s	-25
59:53.8	X	ABC	0.030 s	-27
59:53.9	X	ABC	0.020 s	-25.6
21:59.9	Y	ABC	0.070 s	-15.3
59:53.9	X	ABC	0.020 s	-30.8
59:53.9	X	ABC	0.030 s	-28.6
59:54.0	X	ABC	0.030 s	-32.5
22:00.1	Y	ABC	0.030 s	-15.3
59:54.0	X	ABC	0.030 s	-33.6
59:54.1	X	ABC	0.020 s	-32.2
59:54.1	X	ABC	0.020 s	-34.4
22:00.2	Y	ABC	0.110 s	-15.3
59:54.2	X	ABC	0.020 s	-34.9
59:54.2	X	ABC	0.020 s	-36.5
59:54.2	X	ABC	0.030 s	-39.5
59:54.3	X	ABC	0.030 s	-39
22:00.6	Y	ABC	0.110 s	-15.4
59:54.3	X	ABC	0.020 s	-39
59:54.3	X	ABC	0.060 s	-41.8
22:06.5	Y	ABC	0.380 s	-16.4

5 Voltage dip window

The table below is the typical Voltage Dip Window for the classification of Dips taken from the Quality of Supply standards NRS 048-2.

Magnitude of voltage depression  
(Decrease below nominal)

