

## ANNEXURE A

### 1. Tender Requirements

This tender is a request for the supply and installation of a 40kVA UPS system as per specifications below.

The supplier is required to state compliance to each requirement by indicating in the 'COMPLIANCE' column.

### 2. Equipment Specifications

SPECIFICATION	COMPLY
40kVA, 400V input / 400V output (adjustable) UPS	
3 Phase input power.	
Must be able to carry a load of 80% of the 40kVA capacity for minimum 1 hour.	
Must be generator compatible.	
Network Manageable – including shutdown software agents on all connected devices (PC's and servers).	
Manual maintenance bypass.	
LED/LCD Status indicators.	
Parallel-capacity capable (be able to connected 2 or more UPS devices to increase total power output capacity).	
Use maintenance free, hot swappable, lead acid batteries.	
Audible alarms (that can be disabled).	
Automatic self tests.	
Input power factor correction.	
Intelligent battery maintenance.	
At least 3 years guaranteed battery life	

### 3. PRICING

Cost Must include installation and delivery costs.

### 4. Delivery period

Specify expected delivery date for the equipment.